

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

## CERTIFICATE

No.: 1180761

**Product:** Flexible wiring pipes with metal cover and accessories

**Type:** 3313, 3316, 3326, 3329, 3336, 3348

**Rating:** -45°C až +90°C

**Ordering firm:** KOPOS KOLÍN a.s.  
Havlíčková 432, 280 94 Kolín IV, Czech Republic

**Manufacturer:** KOPOS KOLÍN a.s.  
Havlíčková 432, 280 94 Kolín IV, Czech Republic

**Trade mark:**

**The test results are stated in the test-report No.:** 803219-01/01 of: 30.10.2018

**A sample of the product was found to be in conformity with:**  
ČSN EN 61386-1 ed. 2:09, ČSN EN 61386-22:04+A11:11

**Other data:** TP-KO-01/98


Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 803219 between the client and the Electrotechnical Testing Institute.

**Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.**

**The validity of the certificate is limited to:** 30.11.2021

08.11.2018

Prague

  
Mgr. Miroslav Sedláček  
Head of Certification Body



803219-01