

product description:

designed for distribution system with voltage 400 V
 the body of the box is provided with a fixture for connection to the cover KBV-2/71
 the perimeter of the box body contains pre-marked holes to drill inlets for pipes of EN 20 and 25, inlets can easily be made in the desired locations using a drill and the respective drilling blade
 possibility to join into continuous series with spacing of 71 mm
 the design of the bottom allows inserting a pipe of diameter 20 allowing interconnection of boxes

material: PP (halogen-free)

color: orange

self-snuffing: no

temperature resistance: -5 - +60 °C (short-time +90 °C)

flaming loop test: 650 °C

fire class for underlying material: A1

weight: 25 g

meets the requirements: EN 60 670-1

storage: ČSN 64 0090

KBT-3/71_AB - 10 pcs of bodies of the box packed in foil, labeled; 100 pcs of bodies of the box in carton

Example of using one-sided mounting

Cover KBV-2/71 is mounted to the fixed part of the casing. To the body KBT-3/71 is prepared inputs for pipes and pushed to the already fixed cover KBV-2/71.

Spacing pipe 8020 is inserted to support KBP-1/71 as well as the four rods KBP-8. The back part of the set assembled in this way is slipped over the already mounted box and cover. Wiring pipes is installed to final set. The manufacturer recommends using a flexible pipes LPE (23xx/LPE-x).

The system can be completed from the side of the support KBP-1 which is mounted to the fixed part of the casing.


Parts allow joining more sets into continuous series with spacing of 71 mm, suitable for multiple frames.

Calculate the length of the spacer pipe and rods:

min. wall thickness = min. length set = 80 mm (L)

length of spacing rods (mm) = L - 20

length of spacing pipe 8020 (mm) = L - 65



Example of using double-sided mounting

Cover KBV-2/71 is mounted to the fixed part of the casing. To the body KBT-3/71 is prepared inputs for pipes and pushed to the already fixed cover KBV-2/71.

The other box is assembled, pipe 8020 is inserted as well as four rods KBP-8. The back part of the set assembled in this way is slipped over the already mounted box and cover. Wiring pipes is installed to final set. The manufacturer recommends using a flexible pipes LPE (23xx/LPE-x).

Parts allow joining more sets into continuous series with spacing of 71 mm, suitable for multiple frames.

Calculate the length of the spacer pipe and rods:

min. wall thickness = min. length set = 125 mm (L)

length of spacing rods (mm) = L - 10

length of spacing pipe 8020 (mm) = L - 110



Before pouring concrete mixture, we recommend tying the system to reinforcements by means of draw bands and sealing passages around tubes using sealing material.

When the concrete mix is mature and the casing is dismantled, the break-off bottom of the cover KBV-2/71 is removed and final electrical wiring is made inside the KBT-3/71 boxes.

The extending frames NRB 60/12 and NRB 60/24 are used to adjust the height of and box during subsequent application of and plaster.